



PROJECT & SITE

CLIENT	PROJECT	PROJECT CODE	STATE
City of Lebanon Water	Drinking Water Compliance — Q1	LEB-DW-Q1	NH
SITE NAME	SITE CODE	SITE TYPE	GPS
Lebanon Treatment Plant Finished	LEB-FIN	drinking well	43.6428, -72.2518

SAMPLING EVENT

SAMPLER	COLLECTED	WEATHER	AIR TEMP	RECEIPT TEMP
Ben Aldrich	6/8/2026, 9:32:51 PM	Clear	0.4 °C	4.4 °C

FIELD READINGS AT COLLECTION

PH	COND. (µS/CM)	DO (MG/L)	TEMP (°C)	ORP (MV)	TURB. (NTU)
7.89	297	6.90	11.5	116	1.27

GROUNDWATER PURGE LOG

PURGE VOLUME (L)	DRAWDOWN (M)	PUMP RATE	STABILIZED
39.8	0.24	0.5 L/min	3 well volumes

SHIPPING & COOLER RECEIPT

CARRIER	TRACKING	COOLER ID	COOLER TEMP	BLANK	STATUS
FedEx	7694051217543	CLR-471	2.1 °C		SEALED
TAMPER SEALS		SEALS INTACT	# CONTAINERS		SEALED
100467,100468		YES	3		—

SAMPLE CONTAINERS

ACCESSION	CONTAINER	PRES.	MATRIX	VOL (ML/G)	RECEIPT COND.	PH	CHK	PRES. OK	TESTS REQUESTED
ENV-2026-04482	40mL VOA vial	HCl	WATER	40	INTACT	1.4		YES	EPA 524.2
ENV-2026-04483	250mL HDPE	HNO3	WATER	250	INTACT	1.6		YES	EPA 200.8
ENV-2026-04484	120mL sterile	iced	WATER	120	INTACT	n/a		YES	SM 9223B

CHAIN OF CUSTODY TRANSFERS

#	RELINQUISHED BY	DATE / TIME	SIGNATURE	RECEIVED BY	DATE / TIME	SIGNATURE
1	Ben Aldrich	6/9/2026, 1:32:51 AM	Ben Aldrich	Endyne Courier	6/9/2026, 1:57:41 AM	T. Hill

LABORATORY ACCEPTANCE

Harry Locker

ENDYNE LAB RECEIVING · 6/10/2026, 11:42:41 AM

WITNESS · DATE

This Chain of Custody record documents possession of samples from collection through final analytical result. This report shall not be reproduced except in full, without the written approval of Endyne Inc. Results reported relate only to items tested. Test results meet all requirements of ISO/IEC 17025:2017 and applicable state/EPA accreditation programs except as noted in the Case Narrative.