



**PROJECT & SITE**

CLIENT	PROJECT	PROJECT CODE	STATE
City of Lebanon Water	Lead & Copper Rule Sampling	LEB-LCR	NH
SITE NAME	SITE CODE	SITE TYPE	GPS
Lebanon LCR Tap LCR-014	LEB-LCR-014	drinking well	43.6411, -72.2547

**SAMPLING EVENT**

SAMPLER	COLLECTED	WEATHER	AIR TEMP	RECEIPT TEMP
Riley Thomas	6/9/2026, 12:32:51 AM	Overcast	9.9 °C	3.3 °C

**FIELD READINGS AT COLLECTION**

PH	COND. (µS/CM)	DO (MG/L)	TEMP (°C)	ORP (MV)	TURB. (NTU)
7.32	350	5.84	17.5	166	4.72

**GROUNDWATER PURGE LOG**

PURGE VOLUME (L)	DRAWDOWN (M)	PUMP RATE	STABILIZED
33.7	0.47	0.5 L/min	3 well volumes

**SHIPPING & COOLER RECEIPT**

CARRIER	TRACKING	COOLER ID	COOLER TEMP BLANK	STATUS
FedEx	7932897431333	CLR-373	2.3 °C	SEALED
TAMPER SEALS	SEALS INTACT	# CONTAINERS	SEALED	
100549,100550	YES	1	6/9/2026, 12:32:51 AM	

**SAMPLE CONTAINERS**

ACCESSION	CONTAINER	PRES.	MATRIX	VOL (ML/G)	RECEIPT COND.	PH CHK	PRES. OK	TESTS REQUESTED
ENV-2026-04567	250mL HDPE	HNO3	WATER	250	INTACT	1.3	YES	EPA 200.8

**CHAIN OF CUSTODY TRANSFERS**

#	RELINQUISHED BY	DATE / TIME	SIGNATURE	RECEIVED BY	DATE / TIME	SIGNATURE
1	Riley Thomas	6/9/2026, 4:32:51 AM	Riley Thomas	Endyne Courier	6/9/2026, 5:12:12 AM	T. Hill

**LABORATORY ACCEPTANCE**

*Harry Locker*

ENDYNE LAB RECEIVING · 6/9/2026, 12:32:51 AM

WITNESS · DATE

*This Chain of Custody record documents possession of samples from collection through final analytical result. This report shall not be reproduced except in full, without the written approval of Endyne Inc. Results reported relate only to items tested. Test results meet all requirements of ISO/IEC 17025:2017 and applicable state/EPA accreditation programs except as noted in the Case Narrative.*