



PROJECT & SITE

CLIENT	PROJECT	PROJECT CODE	STATE
City of Lebanon Water	Lead & Copper Rule Sampling	LEB-LCR	NH
SITE NAME	SITE CODE	SITE TYPE	GPS
Lebanon LCR Tap LCR-027	LEB-LCR-027	drinking well	43.6489, -72.2502

SAMPLING EVENT

SAMPLER	COLLECTED	WEATHER	AIR TEMP	RECEIPT TEMP
Ben Aldrich	6/3/2026, 5:32:51 PM	Clear	24.4 °C	4.4 °C

FIELD READINGS AT COLLECTION

PH	COND. (µS/CM)	DO (MG/L)	TEMP (°C)	ORP (MV)	TURB. (NTU)
7.91	717	4.90	16.2	199	3.83

GROUNDWATER PURGE LOG

PURGE VOLUME (L)	DRAWDOWN (M)	PUMP RATE	STABILIZED
12.8	0.10	0.5 L/min	3 well volumes

SHIPPING & COOLER RECEIPT

CARRIER	TRACKING	COOLER ID	COOLER TEMP BLANK	STATUS
Client	—	CLR-115	5.0 °C	SEALED
TAMPER SEALS		SEALS INTACT	# CONTAINERS	SEALED
100647,100648		YES	1	6/3/2026, 5:32:51 PM

SAMPLE CONTAINERS

ACCESSION	CONTAINER	PRES.	MATRIX	VOL (ML/G)	RECEIPT COND.	PH CHK	PRES. OK	TESTS REQUESTED
ENV-2026-04667	250mL HDPE	HNO3	WATER	250	INTACT	1.4	YES	EPA 200.8

CHAIN OF CUSTODY TRANSFERS

#	RELINQUISHED BY	DATE / TIME	SIGNATURE	RECEIVED BY	DATE / TIME	SIGNATURE
1	Ben Aldrich	6/3/2026, 9:32:51 PM	Ben Aldrich	Endyne Courier	6/3/2026, 10:30:07 PM	T. Hill

LABORATORY ACCEPTANCE

Harry Locker

ENDYNE LAB RECEIVING · 6/3/2026, 5:32:51 PM

WITNESS · DATE

This Chain of Custody record documents possession of samples from collection through final analytical result. This report shall not be reproduced except in full, without the written approval of Endyne Inc. Results reported relate only to items tested. Test results meet all requirements of ISO/IEC 17025:2017 and applicable state/EPA accreditation programs except as noted in the Case Narrative.