



**PROJECT & SITE**

CLIENT	PROJECT	PROJECT CODE	STATE
Whitman & Sons (Homeowner)	Private Well Annual	WHITMAN-WELL	VT
SITE NAME	SITE CODE	SITE TYPE	GPS
Whitman Residence — Drilled Well	WHITMAN-W1	drinking well	44.3018, -72.5784

**SAMPLING EVENT**

SAMPLER	COLLECTED	WEATHER	AIR TEMP	RECEIPT TEMP
James Hartwell	5/26/2026, 5:32:51 PM	Clear	6.8 °C	3.9 °C

**FIELD READINGS AT COLLECTION**

PH	COND. (µS/CM)	DO (MG/L)	TEMP (°C)	ORP (MV)	TURB. (NTU)
7.23	451	4.87	15.5	298	2.95

**GROUNDWATER PURGE LOG**

PURGE VOLUME (L)	DRAWDOWN (M)	PUMP RATE	STABILIZED
28.3	0.56	0.5 L/min	3 well volumes

**SHIPPING & COOLER RECEIPT**

CARRIER	TRACKING	COOLER ID	COOLER TEMP	BLANK	STATUS
UPS	1ZW79505TMULSOHIIZ	CLR-239	3.3 °C		SEALED
TAMPER SEALS		SEALS INTACT	# CONTAINERS		SEALED
100679,100680		YES	3		—

**SAMPLE CONTAINERS**

ACCESSION	CONTAINER	PRES.	MATRIX	VOL (ML/G)	RECEIPT COND.	PH	CHK	PRES. OK	TESTS REQUESTED
ENV-2026-04701	40mL VOA vial	HCl	WATER	40	INTACT	1.4		YES	EPA 524.2
ENV-2026-04703	120mL sterile	iced	WATER	120	INTACT	n/a		YES	SM 9223B
ENV-2026-04702	250mL HDPE	HNO3	WATER	250	INTACT	1.5		YES	EPA 200.8

**CHAIN OF CUSTODY TRANSFERS**

#	RELINQUISHED BY	DATE / TIME	SIGNATURE	RECEIVED BY	DATE / TIME	SIGNATURE
1	James Hartwell	5/26/2026, 9:32:51 PM	James Hartwell	Endyne Courier	5/26/2026, 10:35:39 PM	T. Hill

**LABORATORY ACCEPTANCE**

*Harry Locker*

ENDYNE LAB RECEIVING · 6/10/2026, 9:10:42 AM

WITNESS · DATE

*This Chain of Custody record documents possession of samples from collection through final analytical result. This report shall not be reproduced except in full, without the written approval of Endyne Inc. Results reported relate only to items tested. Test results meet all requirements of ISO/IEC 17025:2017 and applicable state/EPA accreditation programs except as noted in the Case Narrative.*